



Department of Works and Engineering

**BUILD, OWN AND OPERATE PLANT
TO PRODUCE POTABLE WATER FOR ST GEORGES
ADDENDUM NO. 1**

DATE: 14th February 2017

METHOD OF DELIVERY:

POSTED ON www.opmp.gov.bm

This Addendum forms part of the RFP documents and will be subject to all of the conditions set out in the contract conditions.

This Addendum One contains (One) page.

Item 1 - Deadline for Submission of Tenders

The closing date for the tender has been extended .Written tender responses to the RFT are now to be received no later than February 27, 2017 at 3:00 p.m. AST, at the Ministry of Public Works, located at 3rd Floor, General Post Office Building, 56 Church Street, Hamilton, Bermuda.

Item 2 - Amendment

Throughout the documents where shown

Replace;

65,000 gals per month

With;

65,000 gals per day

Item 3 – Clarification

Volume 3 part 3.6D indicates the minimum quality criteria for the plant to enter into service and to start to deliver water. The standards set out in Volume 3 Appendix A are the ongoing water quality standards to be applied for the duration of the contract.

Item 4 – Site Meeting Minutes

Following the site visit on Friday 10th February meeting minutes and drawings relating to the minutes are attached to this addendum.

Bidders are requested to acknowledge receipt of this Addendum(one) by emailing tjchristopher@gov.bm

Sincerely, Project Manager

END OF ADDENDUM one