



GOVERNMENT OF BERMUDA
 Ministry of Public Works
 Department of Works and Engineering

(April 22nd, 2019)

Dear Proponent

Ref: 44-11-76 Watford Bridge – Waterproofing and Expansion Joint Replacement

This Addendum # 2 contains (2) pages.

The following addendum supersedes information contained in the RFP to the extent referenced.

This addendum forms part of the RFP documents and will be subject to all of the conditions set out in the contract conditions.

Questions (Q) and Government’s Responses (R).

	TENDER DOCUMENT REFERENCE	ANNEX	ISSUE	QUESTION	ANSWER
1	APPENDIX D - RFP PARTICULARS MANDATORY SUBMISSION REQUIREMENTS		Joint Venture Submission	Would it be better in your opinion to: a) Have a local company head the JV as a local Bermuda based contractor, with a foreign company as their JV partner, or b) Have a foreign company with long experience with bridge deck waterproofing and/ or movement joints head up the JV?	It is the responsibility of the proponents to determine which partner will act as the prime contractor. As noted in the RFP, joint submissions are acceptable, however if a joint submission is made, the submission must clearly indicate which party will act as the prime contractor. <u>Please note that in this case there was a Mandatory Pre-Bid Meeting. The proposal would be considered as long as a representative of the Joint Venture was present (regardless if it is the prime contractor or not).</u>
2	RFP APPENDIX C - PRICING		Import Duties	Could you confirm whether or not, imported materials would be exempt from import duty?	Imported materials would <u>not</u> be exempt from import duty.
3	RFP Drawing S-2	C	Expansion Joints	Please note that the specified asphaltic plug joints are not capable of taking the movement prescribed at the East Side of the bridge (+/- 28mm). Plug joints will also be only just capable of taking the movement to the West Side (+/- 19mm). Can we quote alternative joints which will be capable of handling the expected movements?	Yes. As stated on Drawing S-2, the Ministry of Public Works will consider any option that does not require mechanical fixings to the concrete deck and that is capable of accommodating the specified movements.
4	Addendum 1 Questions (Q) and		Waterproofing providers	Can you please advise if you will be securing a quotation from USL America and passing on to General Contractor’s to carry?	The government will not be securing and passing on a quotation from USL America.



GOVERNMENT OF BERMUDA
Ministry of Public Works
Department of Works and Engineering

	TENDER DOCUMENT REFERENCE	ANNEX	ISSUE	QUESTION	ANSWER

END OF ADDENDUM #2

Note: Amendment/addenda will be posted at <https://www.gov.bm/procurement-notices>. Respondents should visit the Government Portal website on a regular basis during the Procurement process.